

VILLAGE OF RIVER FOREST  
DEPARTMENT OF PUBLIC WORKS



**ADDENDUM # 1**

FOR

2018 GREEN ALLEY IMPROVEMENT PROJECT  
(PHASE 2)

**Due Date: Wednesday, June 19, 2019**

The “Acknowledgement of Receipt” sheet of this addendum **MUST** be included in the proposal package. Proposal packages not including signed Acknowledgement of Receipt Sheet may be rejected.

Clarifications:

1. The plan set currently indicates a permeable paver trench width of 48”. To accommodate a mechanical installation of the Unilock Eco-Optiloc pavers (as specified) without the need for additional cuts or excessive joint spacing, a trench width of 45” will be permitted. This should allow for mechanical installation off the pallet of only solid pavers, without the need for any cuts along the longitudinal sides of the trenches.



VILLAGE OF RIVER FOREST  
DEPARTMENT OF PUBLIC WORKS

**ACKNOWLEDGEMENT OF  
RECEIPT OF ADDENDUM**

PROPOSAL/BID: 2018 GREEN ALLEY IMPROVEMENT PROJECT (PHASE 2)

ADDENDUM #: 1

PROPOSER/BIDDER: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

RECEIVED BY: \_\_\_\_\_  
(NAME)

\_\_\_\_\_  
(SIGNATURE)

DATE: \_\_\_\_\_

**End of Addendum No. 1**